

ANDERSON GREENWOOD H7HP HAND VALVE

$\frac{3}{16}$ " (4.8 mm) orifice hard seated hand valve to ASME B31.1 or B31.3 that meets MSS-SP-105



GENERAL APPLICATION

The H7HP is a globe pattern instrument hand valve used in severe service isolation, drain and test applications providing bubble-tight instrument service .

TECHNICAL DATA

Materials:	CS, SS, Hastelloy®
Seats:	Metal
Connections:	$\frac{1}{4}$ "; $\frac{1}{2}$ "; $\frac{3}{4}$ " NPT, pipe or tube stub. $\frac{1}{2}$ " AGCO tube
Pressure (max.):	6170 psig (426 barg)
Temperature (max.):	1000°F (538°C)

FEATURES

- Graphite stem packing for high-temperature service.
- Free-swivelling SS ball stem prevents seating surface damage, ensures perfect alignment and bubble-tight shutoff.
- One-piece handle assembly prevents loss due to vibration or maintenance.
- Rolled stem threads prevent galling and extend valve life. Stem is polished to a mirror finish to minimize packing wear.
- Back seat design provides secondary stem seal and prevents accidental stem blowout under pressure.
- Full pressure and temperature range up to ASME Class 2500.
- Patented bonnet lock prevents accidental loosening of the bonnet-to-body seal and allows panel mounting without additional parts.
- Metal-to-metal bonnet-to-body seal in constant compression prevents bonnet thread corrosion, eliminates possible tensile breakage and provides a reliable seal point.
- Repairable metal seat can be resurfaced, when not under pressure, without removing the valve from the line.
- Materials of construction designed to meet ASME B31.1 or B31.3.
- Range of optional end connections

ANDERSON GREENWOOD H7HP HAND VALVE

ASME B31.1 OR B31.3

3/16 inch (4.8 mm) ASME B31.1 or B31.3 - meets MSS-SP-105

Valve design criteria is described in Section 107. Important considerations from this section are:

1. Valves require specific pressure and temperature ratings such as those found in ASME B16.34.
2. Material requirements must conform to listed ASTM specifications.
3. As a minimum, the valve body should be marked or tagged in accordance with specification MSS-SP-25.
4. Valve design may include screwed, union or OS&Y bonnets.

The requirements for instrument, control and sampling systems are found in Section 122.

It defines instrument piping as including that from the instrument root valve (or first valve off the main piping line) up to but not including the instrument, transmitter or any other measuring and sensing device.

The instrument valve or manifold must be designed to withstand full system design pressure at the design temperature or the corresponding saturation temperature, for steam service. Even though the instrument will never be subjected to the system temperature, manifold design requires this protection should the root valve fail under operating conditions. If blowdown valves are used between the root valve and the manifold, the manifold design temperature rating need only be 100°F (38°C). However, the pressure rating must be the lesser of 1.5 times the mainline design pressure or the rating of the blowdown valve. The use of commercial grade manifolds (without the manufacturer's certification to ASME B31.1 or B31.3 or if stamped WOG) which meet only the pressure ratings are prohibited unless all other code requirements have been met (such as Table 126.1 in ASME B31.1 or B31.3 for materials, compliance to testing requirements, etc).

Section I, 137 of the Code specifies the criteria for testing. All instrument manifold valves are required to be hydrostatically tested by the manufacturer to certify compliance. As a minimum, hydrostatic testing is performed to MSS-SP-61. This includes the body cavity hydrostatic test at 1.5 times the design pressure rating and seat leakage test(s) at 1.1 times the maximum pressure rating.

PRESSURE AND TEMPERATURE RATINGS

Body material	Pressure and temperature ratings
SS, A479-316	6000 psig at 100°F (414 barg at 38°C) 3030 psig at 1000°F (209 barg at 538°C)
CS, A105	6170 psig at 100°F (426 barg at 38°C) 3430 psig at 800°F (237 barg at 426°C)
Hastelloy®	6250 psig at 100°F (431 barg at 38°C) 4230 psig at 800°F (292 barg at 426°C)

NOTES

1. All B31.1 or B31.3 products are ASME Class 2500.
2. Approximate valve weight: 1.3 lb (0.6 kg). Orifice size 0.187 inch (4.8 mm). Valve Cv 0.52 maximum.

ANDERSON GREENWOOD H7HP HAND VALVE

BONNET ASSEMBLIES

The H7HP features a metal-seated bonnet assembly which has a rotating stem with free swivel ball-type seat for long service life. The stem threads are rolled and lubricated to prevent galling and reduce operating torque. The high-temperature bonnet assembly uses a strengthened stem and bonnet, incorporating adjustable graphite rings and back-up pressure rings to ensure a leak-free stem seal and a larger size T-bar handle. The specially hardened ball seat is ideal for both steam and liquid service. All bonnets are assembled with a bonnet locking device to prevent accidental removal while in service.

All H7HP model valves are hydrostatic tested to MSS-SP-105 requirements.

HARD SEATED VALVES - H7 ASME B31.1 OR B31.3

3/16 inch (4.8 mm) ASME B31.1 or B31.3

SELECTION GUIDE - POWER INDUSTRY APPLICATIONS^[1]

Example:	H7HP	S	-4Q -XP	CL00	NOTE
Body material					
C	CS, A105				1. All H7 ASME B31.1 or B31.3 valves come standard with GRAFOIL® packing, integral seats, bonnet locks, and are subjected to hydrostatic testing.
S	SS, A479-316				2. Only available with the 'S' body material option.
J	Hastelloy®				3. Available in O.D. tube sizes only.
Connections (inlet/outlet)					4. Tube stubs (both ends) are 6 inches long x 0.095 inch wall (152 mm long x 2.41 mm wall) (ASME 2500 Class).
2	1/4 inch FNPT x 1/4 inch FNPT				5. Single ferrule is standard. For double ferrule add 'D' (i.e. H7HPS - '4ATD').
2B	1/4 inch pipe S.W. x 1/4 inch pipe S.W. ^[2]				
4Q	1/2 inch FNPT x 1/2 inch FNPT				
4QB	1/2 inch pipe S.W. x 1/2 inch pipe S.W.				
4AT	1/2 inch AGCO tube. x 1/2 inch AGCO tube ^[2, 5]				
4TB	1/2 inch tube S.W. x 1/2 inch tube S.W. ^[2, 3]				
4TC	1/2 inch tube stub x 1/2 inch tube stub ^[2, 4]				
44Q	1/2 inch MNPT x 1/2 inch FNPT				
4QB4	1/2 inch pipe S.W. x 1/2 inch FNPT ^[2]				
46Q	3/4 inch MNPT x 1/2 inch FNPT				
6Q	3/4 inch FNPT x 3/4 inch FNPT ^[2]				
6TB	3/4 inch tube S.W. x 3/4 inch tube S.W. ^[2, 3]				
6QB	3/4 inch pipe S.W. x 3/4 inch pipe S.W. ^[2]				
Options					
CL00	Chlorine cleaning (CL)				
CL01	Chlorine cleaning (CLC)				
OC00	Oxygen clean (OC)				
OC01	Gaseous oxygen clean (GOC)				
OC02	Liquid oxygen cleaning (LOC)				
PM	Panel mount - Grafoil bonnet only				
PMI00	PMI body only				
SG (SG)	Nace edition 2003 /MR0103				
SG3 (SG)	MR0175/ISO15156-3 - latest				
SS	All 316 SS construction				

Neither Emerson, Emerson Automation Solutions, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Anderson Greenwood is a mark owned by one of the companies in the Emerson Automation Solutions business unit of Emerson Electric Co. Emerson Automation Solutions, Emerson and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson.com/FinalControl