

- Issued by : NMI Certin B.V.,
accredited by the national accreditation body (RvA), based on the ISO/IEC 17025, with identification number L029. RvA is signatory member of both the Multi-Lateral Agreement of the European cooperation for Accreditation (EA) and the Mutual Recognition Arrangement of the International Laboratory Accreditation Cooperation (ILAC).
- Applicant : Badger Meter Europa GmbH
Nürtinger Straße 76
72639 Neuffen
Germany
- Measuring instrument : An ultrasonic **water meter**

Manufacturer : Badger GmbH
Type : E-Series
- Test specifications : OIML R49-1:2013
"Water meters intended for the metering of cold potable water and hot water"
- Testing period : November 2015 up to and including July 2016
- Result : The measuring instrument complies with the requirements for class 2 of OIML International Recommendation R49-1:2013, for all performed tests, as reported on the following pages.
- Remark : OIML R49-1:2013 is identical with ISO standard ISO 4064-1:2014.
- Issue date : 19 July 2016

Performed by:

Reviewed by:


Ing. E.D. Beumer
Approvals Expert


Ing. H.S. Schouten
Senior Approvals Expert

